

SAFETY COMPLIANCE CHECKLIST

General

Aisles		29 CFR 1910
	Are aisles marked?	.22(b)(2)
	Width of aisles maintained?	.22(b)(1)
	Are aisles in good condition?	.22(b)(1)
	Are work areas clean?	.22(a)
	Is housekeeping maintained?	.22(a)
	Are mats, grating, etc., used where drainage is needed?	.22(a)(2)
	Are floor openings and floor holes protected?	.23
Stairs		
	Are stair railings of standard height? (30"-34" above surface).	.23(5)(ii)
	Does every stairway having 4 or more treads have a hand rail?	.23(d)(i)
	Are risers uniform in height and conform to proper height?	.24(f)
	Are standard railings provided on the open side of exposed stairs?	.24(h)
Electrical		
	Is temporary wiring in use?	.305(a)(2)
	Are all portable tools properly grounded?	.304(f)
	Are all outlets grounded?	.304(f)
	Are there missing covers on electrical fuse and outlet boxes?	.305(b)(2)
Exits		
	Are building exits adequate?	.36/.37
	Are exits properly marked?	.36/.37
	Does lighting in hallways and exit signs conform to government standards? (20 and 5 foot candles respectively).	.36/.37
	Are exits blocked?	.36/.37
	Any emergency power supply?	.36/.37
Ladders		
	Are any fixed ladders being used that require cages or walls?	.27(d)
	Are ladders used without safety feet?	.25
	Are ladders free from sharp edges and splinters?	.26(b)
	Are step ladders in use under 20' in length?	.25(b)(2)
	Is scaffolding capable of carrying intended load safely?	.28

General (continued)

Misc.		29 CFR 1910
	Are industrial trucks equipped with horn, overhead guard, and capacity sign?	.178(a)(5)
	Are batteries charged in a vented area?	.178(g)(2)
	Do open flames exist in battery room?	.178(g)(11)
	Are fuel tanks filled while engines running?	.178(p)(2)
	Do noise levels conform to government standards?	.95
	Are all exposures from dust, fumes, etc., controlled?	.94
	Is local ventilation good?	.94
	Is the compressed air for cleaning under 30 psi?	.242(b)
	Is personal protective equipment provided and used?	.132
	Is the correct type of respirator being worn by personnel?	.134(e)
	Are "floor load" capacity signs posted throughout the building?	.22(d)(1)
	Are compressed gases being handled improperly?	.101
	Are drums used for storage of flammable liquids properly grounded and bonded?	.107(e)(9)
	Are flammable materials being stored in approved cans and cabinets?	.106(d)(2,3)
	Are materials being properly handled?	.176
	Are separate lunch rooms provided when toxic materials are present?	.141(g)(2)
	Are lunch rooms, restrooms, and service rooms kept clean?	.141(a)(3)
	Are approved type machine guards installed at point-of-operations?	.212(a)(3)(ii)
	Are gears, pulleys, conveyors, chains, properly guarded?	.219(d)
	Are special hand tools being used for placing and removing materials from machines?	.212(a)(3)(iii)
	Are guards provided over foot treadles?	.217(b)(4)(i)
	Are machines firmly anchored to prevent moving?	.212(b)