

SAFETY COMPLIANCE CHECKLIST

Locker Rooms

General		29 CFR 1910
	Do the number of restrooms conform to the Federal standards?	.141(c)(iii)
	Are there separate toilet facilities for each sex?	.141(c)(iii)
	Are lunch rooms, restrooms, and service rooms kept clean?	.141(2)(g)
	Are floors maintained as far as practical, in a dry condition?	.141(3)(ii)
	Are hand soap or similar cleansing agents provided in lavatories and shower areas?	.141(d)(2)(iii)
	Are electrical circuits located near water on GFCI?	
	Are aisles and passageways kept clear?	
Exits		
	Are building exits adequate?	.36/.37
	Are exits properly marked?	.36/.37
	Any emergency power supply?	.36/.37
	Does lighting in hallways and exit signs conform to government standards? (20 foot- and 5 foot-candles respectively).	.36/.37
	Are exits unblocked?	.36/.37
Postings		
	Is the OSHA 2203 poster properly displayed?	1903
	Is the EEOC's Americans With Disabilities poster displayed?	
	Is the Form 200, Injury and Illness Reporting Form posted during the month of February?	1904
	Are all OSHA citations for the warehouse area displayed near where the violation occurred?	1903
Fire Protection		
	Are all fire extinguishers accessible, and their locations clearly designed?	.157
	Are all fire extinguishers inspected and recharged regularly, and noted on the inspection tag?	.157
	Are all OSHA citations for this area displayed near where the violation occurred?	1903