

## SAFETY COMPLIANCE CHECKLIST

<b>Maintenance Areas</b>		
<b>House-keeping</b>		29 CFR 1910
	Are aisles marked?	.22
	Width of aisles maintained?	.22
	Are aisles in good condition?	.22
	Are work areas clean?	.22
	Is housekeeping maintained?	.22
<b>Exits</b>		
	Are building exits adequate?	.36/.37
	Are exits properly marked?	.36/.37
	Any emergency power supply?	.36/.37
	Does lighting in hallways and exit signs conform to government standards? (20 and 5 foot candles respectively).	.36/.37
	Are exits blocked?	.36/.37
<b>Fire Protection</b>		
	Are all fire extinguishers accessible, and their locations clearly designed?	.157
	Are all fire extinguishers inspected and recharged regularly, and noted on the inspection tag?	.157
<b>First Aid</b>		
	Are emergency eye wash and shower facilities within the immediate work area where employees are exposed to injurious corrosive materials.	
<b>General</b>		
	Are correct lockout/tagout procedures in use?	.14
	Is compressed air for cleaning under 30 psi?	.242(b)
	Are storage cabinets used to hold flammable liquids, labeled "Flammable - Keep Fire Away"?	.106(d)(3)(ii)
	If carbon monoxide is present, due to forklifts, heaters, or idling vehicles, are signs posted warning of its present?	.1200(f)
	Are flammable liquids, such as gasoline, kept in a safety can?	.144(a)(1)

Maintenance Areas (continued)

<b>Machine Guarding</b>		
	Is all machinery and equipment kept clean and properly maintained?	
	Is sufficient clearance provided around and between machines to allow for safe operations, set up and servicing, material handling, and waste removal?	
	Is equipment and machinery securely placed and anchored to prevent moving?	.212(b)
<b>Portable (Power Operated) Tools and Equipment</b>		
	Are grinders, saws, and similar equipment provided with appropriate safety guards?	.243
	Are power tools used with the correct shield, guard, or attachment recommended by the manufacturer?	.243
	Are rotating or moving parts of equipment guarded to prevent physical contact?	.243
	Are all cord-connected, electrically-operated, tools used by employees at their workplace in good condition?	.243
	Are appropriate safety glasses, face shields, etc., used while using hand tools or equipment that might produce flying materials or be subject to breakage?	1910 Sub 1
	Are MSDS's current?	
	Are tools that are not in use stored safety?	
	Is ventilation adequate?	
	Are cranes and hoists inspections current?	
	Are electrical equipment cords in good condition?	
	Is emergency lighting operable?	