

SAFETY COMPLIANCE CHECKLIST

Spray Paint Operations

General		29 CFR 1910
	Are all exposures from dust, fumes, etc., controlled?	.94
	Is local ventilation good?	.94
	Is the compressed air for cleaning under 30 psi?	.242(b)
	Is personal protective equipment (PPE) provided and used?	.132
	Is correct type of respirator being worn by personnel?	.132(e)
	Are all chemicals used in spray painting operations correctly labeled?	.1200(f)
Ventilation		
	Is adequate ventilation assured before spray operations are started?	.107
	Is mechanical ventilation provided when spraying operations are done in enclosed areas?	.107
	When mechanical ventilation is provided during spraying operations, is it so arranged that it will not circulate the contaminated air?	.107
	Is spray booth completely ventilated before using the drying apparatus?	.107
	Do all drying spaces have adequate ventilation?	.107
	Is the electric drying apparatus properly grounded?	.107
	Are lighting fixtures for spray booths located outside of the booth and the interior lighted through sealed clear panels?	.107
	Are electric motors for exhaust fans placed outside booths or ducts?	.107
	Are belts and pulleys inside the booth fully enclosed?	.107
	Do ducts have access doors to allow cleaning?	.107
	Is the spray area free of hot surfaces?	.107
	Is the spray area at least 20 feet from flames, sparks, operating electrical motors, and other ignition sources?	.107
	Are portable lamps used to illuminate spray areas suitable for use in a hazardous location?	.107
	Is approved respiratory equipment provided and used when appropriate during spraying operations?	.107
Fire Protection		
	Are all fire extinguishers accessible, and their locations clearly designed?	.157
	Are all fire extinguishers inspected and recharged regularly, and noted on the inspection tag?	.157

Spray Paint Operations (continued)

	Do solvents used for cleaning have a flash point of 100 deg. F or more?	.107(g)(5)
	For a fixed extinguishing system, is a sign posted warning of the hazards presented by the extinguishing medium?	.160(b)(5)
	Are fire control sprinkler heads kept clean?	.107
	Are "No Smoking" signs posted in spray areas, paint rooms, paint booths, and paint storage areas?	.107(g)(7)
	Is the spray area kept clean of combustible residue?	.107
	Are spray booths constructed of metal, masonry, or other substantial noncombustible material?	.107
	Are spray booth floors and baffles noncombustible and easily cleaned?	.107
	Is infrared drying apparatus kept out of the spray area during spraying operations?	.107
	Are spray painting operations done in spray rooms or booths equipped with an appropriate exhaust system?	.107
	Are all tools used for cleaning purposes made of non-sparking material?	.107(g)(2)
First Aid		
	Are emergency eye wash and shower facilities within the immediate work area where employees are exposed to injurious corrosive materials?	.151(c)
Personal Protective Equipment		
	Are protective goggles or face shields provided and worn where there is any danger of flying particles or corrosive materials?	.133
	Are approved safety glasses required to be worn at all times in areas where there is a risk of eye injuries such as punctures, abrasions, contusions, or burns?	.133
	Are protective gloves, aprons, shields, or other means provided against cuts, corrosive liquids, and chemicals?	.132
	Are employees who need corrective lenses (glasses or contacts) in working environments having harmful exposures required to wear only approved safety glasses, protective goggles, or use other medically approved precautionary procedures?	.133(a)(3)
	Is storage of combustibles with MSDS's acceptable?	
	Inspect electrical cords, belts, pulleys?	
	Is respiratory equipment easily accessible?	
	Is emergency lighting operable?	
	Is each spray booth at least 3 feet from other operations?	.107(b)