

SAFETY COMPLIANCE CHECKLIST

Scaffolds

	Is the footing or anchorage for scaffolds sound rigid?	29 CFR 1910.28
	Are screw jacks used to level scaffold instead of unstable objects such as concrete block, loose, bricks, etc.?	
	Is guard railing and toeboard provided on scaffold with open side above 10'?	
	Are working level platforms fully planked?	1910.28
	Do scaffold planks extend over their end planks not less than 6 inches nor more than 18 inches?	
	Scaffolds free of hazards from the accumulation of tools, material, and debris?	
	Is overhead protection provide to employees who are exposed to overhead hazards?	1910.28

Ladders

	Are ladders inspected semi-annually with a record of inspection on file?	
	Are joints between steps and side rails tight?	
	Do movable parts operate freely without binding or undue play?	
	Are defective ladders removed from service and tagged "Do Not Operate" ?	
	Are extension ladders tied off or held while being used?	
	Are metal ladders restricted from use near electrical work?	
	Has a proper storage location been established for ladders?	